

## ADDENDUM #1

Stephen Olney Elementary School  
1378 Douglas Avenue  
North Providence, RI

Project No. 17025.21

This Addendum dated August 13, 2020 forms a part of the Contract Documents and modifies the original Bidding Documents dated March 3, 2020. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum is comprised of the following attachments:

1. Previously issued Drawings, dated 3/03/20, revised 8/13/2020:
  - a. L001 General Site Information
  - b. L203 Site materials and Layout
  - c. L301 Site Grading
  - d. L501 Site Details
  - e. L302 Drainage Plan
  
2. Response to Bid Questions:
  - a. Clarification: The Owner will have the demolished curbing currently stockpiled on site removed prior to the work detailed in this bid beginning.
  - b. Confirm whether bid alternate for drainage should be included? **Response: Refer to Revised Sheet L302. Reference and scope for a Bid Alternate has been removed from drawings.**
  - c. Provide information regarding the original retaining wall's manufacturer so that the same material can be used to extend the wall. **The site gravity wall previously submitted was Versa-Lok, Bronco Block.**
  - d. Confirm scope of paving of existing lot. Does the existing catch basin (shown on the drawings) need to be raised? **Refer to Revised Sheet L203 for area of new top coat at existing parking. Provide parking stripping and directional arrows as shown. Note added for extent of demolition of existing curb. Confirm elevation of existing drainage structure (L301) and note added to align with new pavement elevation**

END OF ADDENDUM #1